

I
 COMPANY NAME LG ELECTRONICS INDIA PVT. LTD.
 SITE LOCATION Surajpur, Greater Noida
 TYPE OF WORK AT LOCATION Conference Room

II

AC SPEC.				
S.NO.	BRAND NAME	YEAR	MODEL	CAPACITY
1	LG		Inverter AC	4 Tn
2				
3				
4				

III

CLIMATIC CONDITION (FROM MET DEPTT. REPORTS)		
DATE	OUTSIDE TEMPERATURE	CLOUDY/RAIN (Y/N)
22/4/15	40°	N

IV


BYPASS MODE (WITHOUT MAS- ENERGY)								
START				END				TOTAL UNITS CONSUMED (DIFF. OF A & B)
DATE	START TIME	A. METER READING (KWH)	ROOM TEMPERATURE	DATE	END TIME	B. METER READING (KWH)	ROOM TEMPERATURE	
22/4/15	2:43	58.9	31°C	22/4/15	3:43	61.2	29°C	2.3

V

POWER SAVER MODE (WITH MAS- ENERGY)								
START				END				TOTAL UNITS CONSUMED (DIFF. OF A & B)
DATE	START TIME	A. METER READING (KWH)	ROOM TEMPERATURE	DATE	END TIME	B. METER READING (KWH)	ROOM TEMPERATURE	
22/4/15	4:6	62.0	31°C	22/4/15	5:6	63.7	29°C	1.7

VI
 SAVINGS: (DIFF. IN TOTAL UNITS CONSUMED IN POWER SAVER MODE AND IN BYPASS MODE) 26%

VII
 COMMENTS/OBSERVATIONS IF ANY: Temperature is maintained with & will not e.

CUSTOMER'S SIGNATURE

 STAMP
 CUSTOMER NAME Devendra Sharma
 DESIGNATION 9899302193
 CONTACT NO.
 DATE

TECH. REP. FOR MAGNATRON INTERNATIONAL
 SIGNATURE Basak
 NAME Saptak Basak
 DATE 22/4/15

NR: CUSTOMER IS REQUESTED TO NOTE ALL KWH METER READINGS AND OTHER RELEVANT RECORDS MENTIONED FOR PROPER VALIDATIONS